

Subject: [External] Norm Johnson - Response to ABP System Design Criteria Feedback Request



EXT Johnson, Norman [REDACTED]
to IPA.Solar

Tue, May 18, 2:15 PM (8 days ago)

You are viewing an attached message. InClime Mail can't verify the authenticity of attached messages.

For your consideration:

C. Azimuth

1. Systems with an azimuth of less than 90 degrees and or greater than 270 degrees should be prohibited from ABP participation.

E. Distribute Generation Disclosure Form

All comments relate to system purchase, lease & PPA greater than 25kW systems

1. Shading information / impact, verified by date stamped photo's and or aerial imaging , should be included on the Disclosure.

A. A threshold kWh production loss of 25% , due to shading, should prohibit ABP participation

Your work is greatly appreciated.

Have an outstanding afternoon

Norm Johnson



www.solarpowerprofessor.com



Independence Renewable Energy

@IREnergy

A portion of all revenue is used to support [Convey of Hope](#)



This email has been checked for viruses by Avast antivirus software.

www.avast.com