
From: Bernstein, Kristin [REDACTED]
Sent: Monday, November 1, 2021 9:36 AM
To: IPA.Solar
Subject: [External] Ameresco, Inc - Response to Public Schools Feedback Request

To whom it may concern,

We would like to provide feedback on question C about proposed size categories. We do not believe the proposed size categories allocations are appropriate. Most schools do not have land that they can allocate to ground mount systems, limiting the size of their systems to the capacities of their roofs. Only very large schools can host even near 1 MW of capacity. Most schools have space for less than 500kW. We recommend that the size categories and allocation change to represent realistic system sizes as well as to encourage the more economical larger systems. We recommend 25% to less than 250kW, 50% to 250kW-1MW, and 25% to over 1MW.

Regards,
Kristin



Kristin Bernstein, P.E., CEM, NABCEP Certified PV Installation Professional™
Senior Project Development Engineer

P: [REDACTED]

1900 Spring Road, Suite 400
Oak Brook, IL 60523
<http://www.ameresco.com>

NOTE: This e-mail may contain PRIVILEGED and CONFIDENTIAL information and is intended only for the use of the specific individual(s) to which it is addressed. If you are not an intended recipient of this e-mail, you are hereby notified that any unauthorized use, dissemination or copying of this e-mail or the information contained in it or attached to it is strictly prohibited. If you have received this e-mail in error, please delete it and immediately notify the person named above by reply e-mail. Thank you.